

DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria

Declares that the

Product: SensoIRIS S130

Description: Analogue addressable fire alarm optical- smoke detector

Complies to the following standards:

EN 54-7:2018

EN 55032:2015

EN 50130-4:2011; EN 50130-4:2011/A1:2014

The following Regulation:

CPR № 305/2011

REACH No 1907/2006

And the following Directives:

2014/30/EU - EMC

2011/65/EU – RoHS II

Additional information:

First date of production: 09.2011

Certificate:

№ 1293–CPR-0452-Rev.2 of November 6th, 2023 from Notified body № 1293 EVPU

Test report:

№ C08/21/0026/4204/SL-2 of May 20, 2022 from Notified body № 1293 EVPU

Note: To be used in conjunction with base B124.

2, Iliyansko shose Str.
NPZ Voenna Rampa
1220 Sofia, Bulgaria
08.12.2023

Yuliy Iliev
Quality Manager

