

## Declaration of performance

№ 005/2017

According to Construction Products Regulation EU № 305/2011

1. *Unique identification code of the product-type:*

**SensoIRIS WSOU IS - R**

2. *Type Number:*

**SensoIRIS WSOU IS – R**

R - red plastic cover

The Declaration of performance is valid also for the following:

WT - white transparent plastic cover

AT - amber transparent plastic cover

RT - red transparent plastic cover

*Description:* **Intelligent Analog Addressable Fire Alarm Type A Indoor Wall Sounder with build-in Short Circuit isolator Module**

3. *Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer*

**Fire detection and fire alarm systems installed in and around buildings**

4. *Manufacturer*

**Teletek Electronics JSC  
14A Srebarna Str.  
1407 Sofia, Bulgaria**

5. *Trading Company*

**Teletek Electronics JSC  
14A Srebarna Str.  
1407 Sofia, Bulgaria**

6. *System of assessment*

**System 1**


7. *a) Notified Body*

**BRE Global Assurance (Ireland) Limited  
DCU Alpha, Old Finglas Road, Glasnevin, Dublin, D11 KXN4, Ireland**

*Notified Body Number*

**2831**

*Performed* **the prescribed tests and evaluation of factory production control**



according to system 1 and issued the following certificate

*EC Certificate Number*                      **1139e - 03 (Issue 03)**

7. *b) Notified Body*

**EVPU a.s.  
19 Trencianska Str.  
018 51 Nova Dubnica, Slovakia**

*Notified Body Number*                      **1293**

*Performed*    **the prescribed tests and evaluation of factory production control according to system 1 and issued the following certificate**

*EC Certificate Number*                      **1293- CPR-0464 Rev.1**

8. *No European Technical Assessment has been issued for this product.*

9. *Declared performance*

<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonized technical specification EN 54-3:2014+A1:2019</b>
Performance under fire condition	Pass	4.2, 4.3, 5.2, 5.3
Operational reliability	Pass	4.4, 4.5, 4.6, 5.4
Durability of operational reliability: temperature resistance	Pass	5.5, 5.6, 5.7, 5.8, 5.9
Durability of operational reliability: humidity resistance	Pass	5.8, 5.9, 5.10
Durability of operational reliability: corrosion resistance	Pass	5.11
Durability of operational reliability: shock and vibration resistance	Pass	5.12 to 5.15
Durability of operational reliability; electrical stability	Pass	5.16
Durability of operational reliability: resistance to ingress	Pass	5.17

<b>Essential characteristics</b>	<b>Performance</b>	<b>Harmonized technical specification EN 54-17:2005</b>
Operational reliability	Pass	cl. 4

Performance parameters under fire conditions	Pass	cl. 5.2
Durability of Nominal activation condition / Sensitivity; Temperature resistance	Pass	cl. 5.4, 5.5
Durability of Nominal activation condition / Sensitivity; Humidity resistance	Pass	cl. 5.6, 5.7
Durability of Nominal activation condition / Sensitivity; Corrosion resistance	Pass	cl. 5.8
Durability of Nominal activation condition / Sensitivity; Vibration resistance	Pass	cl. 5.9 to 5.12
Durability of Nominal activation condition / Sensitivity; Electrical stability	Pass	cl. 5.3, 5.13

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

1407 Sofia,  
14A, Srebarna Str.  
26.09.2022

Yuliy Iliev  
Quality Manager

