



DECLARATION OF CONFORMITY

We, Teletek Electronics JSC
Address: 14A, Srebarna Str.
1407 Sofia, Bulgaria

Declares that the

Product: SensoIRIS WSOU IS

Description: Intelligent Analog Addressable Fire Alarm Type A Indoor Wall
Sounder with build-in Short Circuit isolator Module

Complies to the following standards:

EN 55032:2015
EN 50130-4:2011; EN 50130-4:2011/A1:2014
EN 54-3:2014 + A1:2019
EN 54-17:2005

The following Regulation:

CPR № 305/2011
REACH № 1907/2006

And the following Directives:

2014/30/EU - EMC
2011/65/EU – RoHS II

Additional information:

First date of production: 11.2013

Certificate:

№1139e/03 of September 22, 2022 from Notified body № 2831 LPCB
№1293-CPR-0464-Rev.1 of August 10, 2017 from Notified body № 1293 EVPU

Test report:

№ 00512E/2014 of January 19, 2015 from Notified body № 1293 EVPU
№ TE-E123439-1000 of October 13, 2016 from Notified body № 0832 LPCB

Note: Sounder SensoIRIS WSOU IS-R is compatible with fire bases SensoIRIS B124 and SensoIRIS WSB IP65

1407 Sofia,
14A, Srebarna Str.
26.09.2022

Yuliy Iliev
Quality Manager

